



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO – ws/lab/1450/2025

Date – 30/06/2025

To

The Principal,

Gayatri International School,

Charholi.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Gayatri International School, Charholi on Date: 26/06/2025 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /1448/2025 dated 27/06/2025 & ws /lab /1442/2025 dated 27/06/2025 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp
Nigdi, Pune 44



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - Gayatri International School.

No-WS/LAB/1448/2025.

Date - 27 / 06 / 2025.

ADDRESS - Charholi.

Date of Receipt - 26 / 06 / 2025.

SOURCE - Filter Water.

Date of Examination - 26 / 06 / 2025.

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	0.49 NTU.		
2	pH	6.5 to 8.5	7.55		
3	Total Hardness (as CaCO ₃)	200 mg/lit	36 mg/lit		
4	Chloride	250 mg/lit	24 mg/lit		
5	Calcium	75 mg/lit	9.61 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST

WATER TREATMENT PLANT, NIGDI, PCMC



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

No-WS/LAB/1442/2025


Date - 27 / 06 / 2025.

DATE OF EXAMINATION - 26 / 06 / 2025.

NAME - Gayatri International School

ADDRESS - Charholi.

SOURCE - Filter Water.

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	Nil	0/100ml	-	Potable.
2			 CHIEF CHEMIST Water Treatment Plant Pimpri Chinchwad Municipal Corp. Nigdi, Pune 41		
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY